

MODEL MEANING







Enterprise code


Design Number

Frame Rated Current

FUNCTION AND SCOPE OF APPLICATION

This series of fused switch-disconnector is a fuse holder specifically designed for the photovoltaic industry. This series of products can incorporate fuses and is used for overcurrent protection in main circuits and equipment with a rated voltage not exceeding DC 1000V, a rated current not exceeding 30A, and a rated short-circuit capacity not exceeding 30kA. Mainly used in energy storage systems, solar photovoltaic combiner boxes, as short circuit and overload protection for solar photovoltaic power generation devices, batteries and other semiconductor equipment.

DIMENSIONS (MM)









DC Fuse • SRD-30







Technical Parameters

| Model | SRD-30 (Fused switch-disconnector) | SRF-30 (Fuse Link) |
|-------------------------------------|------------------------------------|-----------------------------------|
| Normative references | IEC/EN60947-1 IEC/EN 60947-3 | EN 60269-1 EN 60269-6 |
| Rated insulation voltage (Ui) | 1200v | / |
| Rated operational voltage (Ue) | DC1100V | DC1000V |
| Rated operating current (le) | 1A-30A | 6A、8A、10A、12A、15A、16A、20A、25A、30A |
| Impulse withstands voltage (Uimp) | 6kV | 1 |
| Rated accepted dissipative power | ≤4W | ≤4W |
| Number of poles | 1P | 1 |
| Rated limited short-circuit current | 30KA | 20KA |
| Matched fuse size | ∮ 10×38mm | ∮ 10×38mm |
| Protection class | IP20 | 7 |
| Use category: | PV-0 | PV-0 |
| Installation Method | 35mm DIN rail | 1 |
| Wiring capacity | 1-10mm² | t. |
| Wiring screw/Terminal block torque | M5 / 1.8-2.3N.m | 1 |
| Stripped wire length | 13mm | Ī |

NORMAL USE AND INSTALLATION CONDITIONS

- Operating temperature -40°C ~ +85°C
- Altitude: ≤ 2,000m
- Pollution degree: Level 3
- Installation category: Class II, Class III
- Installation method: Installed on the standard guide rail, the standard guide rail should meet the requirements of TH35-7.5 type in JB6525-1992;
- The product should generally be installed vertically, and there should be no significant shock and vibration at the installation place;







