

SQ8T-63

Automatic transfer switch





📍 Add: Xinguang Industrial Zone, Liushi, Yueqing Zhejiang China

☎ Tel: +86-577-62890205

✉ E-mail: xinyi@chinasuntree.com

🌐 www.chinasuntree.com

PRODUCT OVERVIEW

automatic transfer switch is a PC class infrequent change-over switch, with two-station design (commonly used for A and standby for B), suitable for AC systems with AC 50-60Hz and rated current 6A-63A. The main function of the automatic transfer switch is when the main power (common power supply A) fails, the ATS will automatically switch to the backup power (Backup power supply B) to continue working (switching speed <50 milliseconds), which can effectively solve the troubles caused by power outages.



SQ8T-63
Automatic transfer switch

model&meaning

S

Company code

Q

Din-rail installation

8

Product Category:
(PC class automatic
transfer
switch (two stations)

-

63

Case grade: 63

/

□

Pole No.: 2P/4P

□

Rated working voltage:
AC220V, AC110V
Rated working current:
6A/10A/16A/20A/25A/32A/40A
50A/63A

working conditions

- The temperature range of the operating environment is $-5^{\circ}\text{C}\sim+40^{\circ}\text{C}$, and the average temperature within 24 hours shall be lower than $+35^{\circ}\text{C}$, and the temperature range of the storage environment is $-25^{\circ}\text{C}\sim+55^{\circ}\text{C}$, which can be reached $+70^{\circ}\text{C}$ in a short time (within 24 hours)
- The altitude of the installation site should be lower than 2000m.
- The relative temperature at the installation site shall not exceed 50% when the ambient air temperature is $+40^{\circ}\text{C}$. Higher relative humidity is possible at lower temperatures. For example: when the average minimum temperature of the wettest month is $+20^{\circ}\text{C}$, the monthly average maximum relative humidity of that month can reach 90%. Appropriate measures should be taken to prevent condensation due to temperature changes.
- Pollution level 3 (conductive pollution, or dry non-conductive pollution becomes conductive due to condensation). ATS can be installed vertically or horizontally in the cabinet, if there are special installation requirements, contact us.
- The protection grade of ATS case is IP30. Overvoltage category Main circuit category III; control and auxiliary circuit category II.

Installation

- Before installation and wiring, please ensure that professionals have read this manual. Before installation, please check the integrity of ATS. Then turn on the ATS with the operating handle, check the flexibility of the operating mechanism, and check the opening and closing status of each phase and normal power and backup power loads.
Please equip the ATS with a suitable circuit breakers according to the installation requirements of the power distribution system to ensure that personnel and equipment safety.

Notes

- Manual/automatic operation can ensure the opening and closing performance of electrical operation, but in manual operation, there is no guarantee due to the different opening/closing speeds of the operators. In manual operation, there's possible for excessive silver alloy loss. Therefore, the selector switch should only be pulled to the manual position after all power has been cut off for inspection and maintenance of the operating system and contact information.
- Normally, pull the selector switch to the electric position. When manual operation is required, pull the selector switch to the manual position. After manual operation is complete, pull the selector switch from the manual position to the automatic position.
The control circuit TSE is immediately energized. After the change over is completed, the internal switch will damage the coil in the control circuit, and the coil can work normally at 85%-110% of the rated operating voltage. Too low input voltage may cause the coil to overheat and burn out.



When manual operation the mode selection switch must be in "manual" position

PRODUCT OVERVIEW


- Maintenance and inspection should be carried out by professionals.
- In order to ensure the good performance of the ATS, the first maintenance and inspection should be carried out within 6 months after use. Then do the maintenance and inspection at least once a year. In harsh installation conditions, the frequency of maintenance and inspection should be increased.
- If the maintenance and inspection items fail, please remove the dust. b: Please check whether the electrical contact parts are deformed and damaged, and clean the surface. c: metal particles and burnt around it.
- Rust, acidification and dust on the contact surfaces can cause poor contact, so do some manual work and measure the necessary contact resistance. d: If the ATS is wet or left unused for a long time, please dry it before turning on the power. After removing the dust, use a 500V megohmmeter to measure the insulation resistance of the normal power supply and the AC power supply.
- The load side and two poles, including the insulation resistance, when using live parts and metal plates, the insulation resistance should not be less than 10MQ.




Main technical parameters

Case grade	63	
Rated operating current Ie(A)	6A/10A/16A/20A/25A/32A/40A/50A/63A	
Rated insulation voltage UL	690V	
Rated impulse withstand voltage Uimp	8kV	
Rated working voltage Ue	AC220V/AC110V	
Rated frequency	50/60Hz	
Class	PC class: can be switched on and loaded without generating short-circuit current	
Pole number	2P	4P
Rated short-circuit current Iq	50kA	
Short circuit protection device (fuse)	RT16-00-63A	
Rated impulse withstand voltage	8kV	
Control circuit	Rated control voltage Us:AC220V, 50Hz Normal working conditions: 85%Us-110%Us	
Auxiliary circuit	AC220V/110V 50Hz Le=5A	
Contactor change-over time	<50ms	
Operation change-over time	<50ms	
Return change-over time	<50ms	
Power off time	<50ms	
Change-over operation time	<50ms	
Mechanical life	≥8000times	
Electrical life	≥1500 times	
Usage category	AC-31B	

Wiring instructions



Dimensions



Note: Terminal wiring area: fit for (1~25)mm².
Wire connection screw is M5, torque: 2.5N.m.